

फोन- 232240
232276


कार्यालय नगर पालिका परिषद कोसीकलाँ (मथुरा)

पत्रांक: P.B.N. 29/26-27

दिनांक: 22/05/26

TO WHOM IT MAY CONCERN

This is to certify that Modern Academy International is a Modern School Complex with modern and hygienic sanitary system. It has 16 toilets for girls and 16 toilets for boys. All property separated by brick wall. It also has 3 lavatories for girls and 4 lavatories for boys. All sanitary facilities including the toilets and lavatories are well serviced for flowing water. Affluent are treated hygienically in proper septic tanks. The entire sanitary system including toilets and lavatoreis are well maintained and regularly cleaned by sweeper.


Sanitary Inspector 22/05/26
सफाई एवं खाद्य निरीक्षक
न०पा०प० कोसीकलाँ (मथुरा)

फोन- 232240

232276

कार्यालय नगर पालिका परिषद

कोसीकलाँ (मथुरा)

पत्रांक: .P.N.S.W-29/26-27

दिनांक: 22/05/26

TO WHOM IT MAY CONCERN

TEST CERTIFICATE

Ref. No. : NIL Issued date :
 Date : Issued to : Modern Academy International
 Opp. Kosi Kalan Restautant
 Kosi Kalan (Mathura) U.P.

Date of Sample Receipt :

S. No.	Test Conducted	Test Result	Desirable	Requirement (IS:10500-1991) Permissible Limited in the absence of alternate source	Test Method
1-	pH	7.4	6.5 × 8.5	No Relaxation	IS:3025 P-11
2-	Colour (Hazen Unit)	<5	5	25	IS:3025 P-4
3-	Taste	Agreeable	Agreeable	-	IS:3025 P-7
4-	Turbidity (NHU)	1.2	5	10	IS:03025 P-10
5-	Odour	Unobjectionable	Unobjectionable	-	IS:3025 P-5
6-	Chloride as Cl, (mg/l)	65	250	1000	IS:3025 P-32
7-	Total Hardness as CaCO ₃ (mg/l)	351	300	600	IS:3025 P-21
8-	Total Iron as Fe. (mg/l)	0.06	0.3	1.0	IS:3025 P-53
9-	Residual free chlorine (mg/l)	Nil	0.2	-	IS:3025 P-26
10-	Fluoride as F, mg/l	1.25	1.0	1.5	APHA20 th Ed
11-	Total Cliform MPN/100 ml	Nil	-	10	IS: 1622
12-	E Coli 10 ml	Nil	-	Nil	IS: 1622

Remarks: The sample of water can be used for drinking purpose.

 22/05/26

सफाई एवं खाद्य निरीक्षक
 न०पा०प० कोसीकलाँ (मथुरा)