

# कार्यालय नगर पालिका परिषद


कोसीकलाँ (मथुरा)

पत्रांक: 11/11/2021-2022

दिनांक: 12/04/2021

## TO WHOM IT MAY CONCERN

This is to certify that Modern Academy International is a Modern School Complex with modern and hygienic sanitary system. It has 7 toilets for girls and 8 toilets for boys. All property separated by brick wall. It also has 3 lavatories for girls and 4 lavatories for boys. All sanitary facilities including the toilets and lavatories are well serviced for flowing water. Affluent are treated hygienically in proper septic tanks. The entire sanitary system including toilets and lavatoreis are well maintained and regularly cleaned by sweeper.

  
12/04/2021  
Sanitary Inspector  
सफाई एवं खाद्य निरीक्षक  
न०पा०प० कोसीकलाँ (मथुरा)



# कार्यालय नगर पालिका परिषद

कोसीकलाँ (मथुरा)

पत्रांक: .....

दिनांक:.....

## TO WHOM IT MAY CONCERN


### TEST CERTIFICATE

Ref. No. : NIL Issued date :  
Date : Issued to : Modern Academy International  
Opp. Kosi Kalan Restautant  
Kosi Kalan (Mathura) U.P.

### Date of Sample Receipt :

S. No.	Test Conducted	Test Result	Desirable	Requirement (IS:10500-1991) Permissible Limited in the absence of alternate source	Test Method
1-	pH	7.4	6.5 × 8.5	No Relaxation	IS:3025 P-11
2-	Colour (Hazen Unit)	<5	5	25	IS:3025 P-4
3-	Taste	Agreeable	Agreeable	-	IS:3025 P-7
4-	Turbidity (NHU)	1.2	5	10	IS:03025 P-10
5-	Odour	Unobjectionable	Unobjectionable	-	IS:3025 P-5
6-	Chloride as Cl, (mg/l)	65	250	1000	IS:3025 P-32
7-	Total Hardness as CaCO <sub>3</sub> (mg/l)	351	300	600	IS:3025 P-21
8-	Total Iron as Fe.(mg/l)	0.06	0.3	1.0	IS:3025 P-53
9-	Residual free chlorine (mg/l)	Nil	0.2	-	IS:3025 P-26
10-	Fluoride as F, mg/l	1.25	1.0	1.5	APHA20 <sup>th</sup> Ed
11-	Total Cliform MPN/100 ml	Nil	-	10	IS: 1622
12-	E Coil 10 ml	Nil	-	Nil	IS: 1622

Remarks: The sample of water can be used for drinking purpose.

  
12/04/2021  
सफाई एवं खाद्य निरीक्षक  
न०पा०प० कोसीकलाँ (मथुरा)